

Government of Bihar

Public Health Engineering Department

Water Quality Test Report

Division Name: Buxar

Sample Collected by :- Bal Vikash Kendra, Hitan, Parari, Staff

District-Buxar		Block	Panchayat	Location	Receiving Date	Testing Date	pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	As	Total Coll.	Remarks	
1	Buxar	Umarpur	Bal Vikash Kendra Hitan, Parari, Umarpur, Buxar	24.10.2025	25.10.2025	7.2	1	225	180	30	48	38	20	40	0.2	5	5	0.2	BDL		Negative	SAFE	
Desirable Limit*							6.5-8.5	1	500	500	200	75	30	250	200	0.3	45	200	1	0.01			
max. permissible limit							NR	5	2000	600	200	100	100	1000	600	1.0	NR	400	1.5	NR			

[Signature]
25/10/2025

Executive Engineer
P.H. Division, Buxar

[Signature]
10/10/25
Chemist

P.H. Division, Buxar

* BDL - Below detection limit.
* NR - Not relaxation.

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1978

Dated: 25/10/2025

It is certified that an inspection team headed by Rahul Kumar Ex: Engineer

(Name of Officers with designation) from P.H. Division Buxar PHED

Inspected the BAL VIKAS KENDRA, HITAN PARARI, UMARPUR, BUXAR, 802118

(Name & Address of the school) on 25.10.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated 25.10.2025

of BUXAR (PHED Lab) certified that

the BAL VIKAS KENDRA (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six month.

Signature with Seal: Rahul Kumar
Name : RAHUL KUMAR
Designation : EXECUTIVE ENGINEER
Name & Address of the Office/ Department : P.H. DIVISION BUXAR

To The Principal
BAL VIKAS KENDRA, HITAN PARARI
(Name & Address of the Institution)
UMARPUR, BUXAR, 802118

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies