

BRIHANMUBAI MUNICIPAL CORPORATION
MUMBAI FIRE BRIGADE

No: FB/Insp/R-III/10
Date: 25/7/2024

Sub :- Fire safety certificate to Narayana e-Techno School
situated at CTS No. 418B, of Marol Village, Near KP Aurum,
Marol Maroshi Road, Andheri East, Mumbai-400059.

Ref :- 1) Letter from M/s Narayana e-Techno School.
2) MFB No.: Insp/R-III/10 dtd. 24/07/2024.

Please refer to your letter under reference to issue Fire safety certificate to existing Narayana e-Techno School building. On receipt of the letter, Senior officer of this department has visited & inspected the site on 24/07/2024.


During the inspection, Mr. Pankaj Nemade Safety Officer of Narayana e-Techno School was present. The school building comprising of Ground floor partly on stilt + 1st to 4th upper floors and this department has already issued Fire safety part compliance report u/n. CE/9170/WS/AK-CFO dated 30/06/2022 to the existing school building and the fire-fighting system such as fire pumps, wet riser cum down comer system, automatic sprinkler system, manual fire alarm system, automatic smoke detection system etc., of the school building are found in good working condition. The fire extinguishers are found on site.

The school authority has appointed M/s. Sai Safety System, Govt. approved license agency (Lic. No. MFS/LA/RF-281/RD-266) and Form 'B' certificate is submitted regarding maintenance and good working condition of existing firefighting installation of the school building as per Maharashtra Fire Prevention and Life Safety Measures Act- 2006.


24/07/2024

A.B. Sonawane
Station Officer
Mumbai Fire Brigade

Copy to M/s Narayana e-Techno School


24/7/24

H. R. Shetty
Dy. Chief Fire Officer
Mumbai Fire Brigade