

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. - 2024-25/585

Dated: 02-12-2024

It is certified that an inspection team headed by Dr. Ram Chandan, Sr. Chemist

(Name of Officers with designation) from Regional Lab Jodhpur PHED

inspected the NARAYANA E-TECHNO SCHOOL, DHAYAL NAGAR JODHPUR

(Name & Address of the school) on 2/12/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 585 dated 2/12/2024

of REGIONAL LABORATORY, JODHPUR (PHED Lab) certified that the NARAYANA E-TECHNO SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 2/12/2025

Signature with Seal: (डॉ. राम चन्द्र)
Name वरिष्ठ रसायनज्ञ
Designation जन स्वास्थ्य अभियान्त्रिक विभाग
Name & Address of the Officer प्रयोगशाला, जोधपुर

To NARAYANA E-TECHNO SCHOOL
DHAYAL NAGAR, JODHPUR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Office of the Superintending Chemist
Public Health Engineering Department, Rajasthan
Regional Laboratory, Jodhpur

Report of The Chemical Examination of Water

No.Lab./Tech.(chem)/2024-25/ 586

Date: 02-12-2024

To
Narayna e-Techno School
Opp. Arihant Adita, Gangana Road,
Dhayal Nagar, Jodhpur

SAMPLE WAS NOT COLLECTED
BY THE LABORATORY

Not for Legal Purpose

Reference No. : Lt. No. ENCS/JOD/2024-25/GEN/04 on Dated 21-11-2024

District : Jodhpur

Date of Receipt : 21-11-2024

Sample Taker : -----

Source	Permissible Value as per B.I.S : 10500/2012		Tap Water
Location			Narayna e-Techno School
Block	Desirable Limit	Permissible limit in absence of alternate Source	----
Village/Town			----
Gram Panchayat			----
Date of Collection			21-11-2024
Date of Examination			26-11-2024
Sample No.			PC-107
Note:- All results except pH are in mg/L			
pH	6.5 to 8.5	No relaxation	7.2
Turbidity(NTU)	1	5	0.2
Colour	5	15	1.1
Odour	Agreeable	Agreeable	Unbjectionable
Temperature	----	----	----
Total Alkalinity	200	600	90
Total Hardness (as CaCO3)	200	600	96
Calcium (as Ca)	75	200	22.4
Magnesium (as Mg)	30	100	9.6
Chloride(as Cl)	250	1000	26
Sulphate(as SO4)	200	400	----
Nitrate as(NO3)	45	45	4.0
Fluoride	1.0	1.5	0.2
Total Dissolved Solids	500	2000	204
Iron	1.0	No Relaxation	----
Residual Chlorine	0.2	1.0	----

Remarks : Water is Potable (P)/Unpotable (U)

Superintending Chemist
PHED Laboratory, Jodhpur

Date:

No.Lab./Tech.(chem)/2024-25/

Copy To :

1. Chief Chemist, State Laboratory Gandhi Nagar, Jaipur

Superintending Chemist
PHED Laboratory, Jodhpur