

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 78

Dated: 29/04/2024

It is certified that an inspection team headed by ... Bharat Singh (A. En.)

(Name of Officers with designation) from ... C.S.D. Digari Jodhpur PHED

inspected the ... Narayana e-Techno School Rukma Nagar Nandani Jodhpur

(Name & Address of the school) on ... 23/04/24 ... (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ... 66/25.04.2024 ... dated ... 25.04.2024

of ... Office of the Sup. Chemist Lab. Jodhpur (PHED Lab) ... certified that

the ... Narayana e-Techno School ... (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ... 24.04.2025

Signature with Seal: ...

Name

Designation

Name & Address of the Office / Department :

To ... Narayana e-Techno School

Rukma Nagar Nandani Jodhpur

(Name & Address of the Institution)

City Sub Division Digari Jodhpur.

सहायक अभियन्ता
जन स्वा. अमि. विभाग
नगर उपखण्ड, डिगाड़ी
जोधपुर (23686)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Office of the Superintending Chemist
Public Health Engineering Department, Rajasthan
Regional Laboratory, Jodhpur

Report of The Chemical Examination of Water

No.Lab./Tech.(chem)/2024-25/ 296

Date: 15-07-2024

To

NARAYANA e-TECHNO SCHOOL
DP Choraha, Laxman Nagar, Nandri
Jodhpur


Reference No : Application Letter No. NES/22 on dated 12.07.2024
Date of Receipt : 15-07-2024

Source	Permissible Value as per B.I.S : 10500/2012		Tap Water
Location			N.e-Tech. School, DP Choraha, Laxman Nagar, Nandri
Other Habitation	Desirable Limit	Permissible limit in absence of alternate Source	-
Village/Town			Jodhpur
Block			-
Date of Collection			12-07-2024
Date of Examination			16-07-2024
Sample No.			PC-53

Note:- All results except pH are in mg/L

pH	6.5 to 8.5	No relaxation	7.8
Turbidity(NTU)	1	5	0.2
Colour	5	15	1.0
Odour	Agreeable	Agreeable	Un-Objectionable
Temperature	----	----	-
Total Alkalinity	200	600	114
Total Hardness (as CaCO ₃)	200	600	120
Calcium (as Ca)	75	200	32.00
Magnesium (as Mg)	30	100	9.60
Chloride(as Cl)	250	1000	32
Sulphate(as SO ₄)	200	400	---
Nitrate (as NO ₃)	45	45	5
Fluoride	1.0	1.5	0.2
Total Dissolved Solids	500	2000	223
Iron	1.0	No Relaxation	---
Residual Chlorine	0.2	1.0	---

Remarks : Water is Potable (P)/Unpotable (U)


Superintending Chemist
PHED Laboratory, Jodhpur
Date:

No.Lab./Tech.(chem)/2024-25/

Copy To :

1. Chief Chemist, State Laboratory Gandhi Nagar, Jaipur

Superintending Chemist
PHED Laboratory, Jodhpur