



BRUHAT BENGALURU MAHANAGARA PALIKE

Medical Officer OF Health, Mahadevapura Division, Bangalore-560048

NO: BBMP/MOH/MDP/PR/ V /2025-26

DATE:-30/05/2025

PROFORMA REGARDING NOC & SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Dr.Rakesh.N,** Medical Officer of Health and **Devraj.M,** Senior Health Inspector from **BBMP Health Department** Inspected the **Narayana Olympiad School, Sy No.42/2, Belathur Village, Bidarahalli Hobli, Bengaluru East Taluk, Bengaluru District-560067.** On **30-05-2025** and found that the **Narayana Olympiad School,** Institution. And is having provision for running water in the toilets and is maintaining the hygienic sanitation condition in the School building & the campus as per the norms prescribed by the Central /state/U.T.Govt.

The Above NOC is Valid for the Period of One Year from the date of Issue.

Signature with Seal :

Name

: **Dr.Rakesh.N**

Designation

: **Medical Officer of Health**

: **BBMP Mahadevapura Division.**

ಆರೋಗ್ಯ ವೈದ್ಯಾಧಿಕಾರಿಗಳು
ಮಹದೇವಪುರ ವಲಯ
ಬೆಂಗಳೂರು

To,

**Narayana Olympiad School,
Sy No.42/2, Belathur Village,
Bidarahalli Hobli,
Bengaluru East Taluk,
Bengaluru District -560067**



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- Narayana Olympiad School Sy.No.42/2, Belthur Village, Bidarahalli Hobli, Bangalore east Taluk Bangalore-560067				Report date: 12/06/2025	
				Report Number: 0008	
				Reference: TRF	
				Sample code: 0008	
				Date of Sample collection: 11/06/2025	
				Analysis start date: 11/06/2025	
				Analysis completion date: 12/06/2025	
Sample quantity: 1 Liter					
Sample Particulars: R O water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.0	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, µS/cm @25°C Temp	120	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	70	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO ₃ , mg/l	17.2	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO ₃ , mg/l	20.0	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	4.8	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	2.0	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	18.7	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO ₄ , mg/l	6.6	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.5	1	1.5	APHA 24 th Edition
14	Nitrate as NO ₃ , mg/l	8.7	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S Senior Analyst/Junior Analyst				Authorized Signatory: Technical Manager: Pavithra B.S	



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) **Traceability:** Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---