



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ನಗರ ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ ಸಿಂಗಸಂದ್ರ, ಬೆಂಗಳೂರು ದ.ತಾ, ಬೆಂ. ನಗರ ಜಿಲ್ಲೆ,

E-mail-dr.singasandra@gmail.com

ಸಂಖ್ಯೆ.ಪ್ರಾ.ಆ.ಕೇ/ಸಿ/25/2025-26

ದಿನಾಂಕ:06-06-2025

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Dr.Vikas S Gowda (MEDICAL OFFICER OF UPHC SINGASANDRA AND PAPARAJU Sr.HIO)** from **HEALTH DEPARMENT** inspected **NARAYANA e-TECHNO SCHOOL SY.NO:31/4, DODDANAGAMANGALA VILLAGE,BEGUR HOBLI,BANGALORE SOUTH TALUK ,BANGALORE URBAN DISTRICT- 560100** on 06-06-2025 and on the basis of Water Test Report (Attached) bearing no-HL/WA/250523017/2025-26 dated-30-05-2025 of (PHED Lab) certified that **NARAYANA e-TECHNO SCHOOL SY.NO:31/4, DODDANAGAMANGALA VILLAGE,BEGUR HOBLI,BANGALORE SOUTH TALUK ,BANGALORE URBAN DISTRICT- 560100** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygiénic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **31-03-2026**

Signature with Seal:

Name

:

DR VIKAS

Designation

:

Medical Officer

Name & Address of the Officer

:

Urban Primary Health Centre

Singasandra

Bengaluru-560100.

To,

NARAYANA e-TECHNO SCHOOL,

**SY.NO:31/4, DODDANAGAMANGALA VILLAGE,BEGUR HOBLI,BANGALORE SOUTH TALUK
BANGALORE URBAN DISTRICT- 560100**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- Narayana E-Techno school Sy.No.31/2, Doddanagamangala Village, Begur Hobli, Bangalore South Taluk, Bangalore Urban Dist. Bangalore-560100				Report date: 12/06/2025	
				Report Number: 0010	
				Reference: TRF	
				Sample code: 0010	
				Date of Sample collection: 11/06/2025	
				Analysis start date: 11/06/2025	
Sample Particulars: R O water				Analysis completion date: 12/06/2025	
				Sample quantity: 1 Liter	
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.1	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	120	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	70	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	21.5	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	28.0	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	6.4	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	3.0	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	9.4	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	5.6	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.4	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	0.2	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S Senior Analyst/Junior Analyst				Authorized Signatory: Pavithra B.S Technical Manager: Pavithra B.S	



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---