



Tumakuru City Corporation, Tumakuru

website : www.tumkurcity.mrc.gov.in
e-mail: itstaff_ulb_tumkur@yahoo.com

Phone: 2278480, Fax: 2275106
Grievance: 0816-2271200, 2272200



No.TCC/HealthSection/CR- /2025-26

Date:09.06.2025

TO,
NARAYANA E-TECHNO SCHOOL
Sy no-297/1,
Sharadadevi Nagara Extension
Tumkur
Tumkuru-572103

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

This is to certify that an Inspection team headed by Dr. Veerayya Kalmath (Health officer) and Manohar (Senior Health Inspector) from Tumakuru city Coporation Health Section inspected the Narayana E-Techno school Sy no 297/1 Sharadadevi Nagar extension Tumakuru -572103 on 06/06/2025 and checked the water test report submitted by the Institution and found that institution has Potable Drinking water for students and staff of the Narayana E-Techno school and is having provision for running water in the toilets and is maintaining the hygienic sanitation condition in the building & the campus as per the norms prescribed by the central /State/U.T.Govt.

The above NOC is valid for The period of one year from the date of Issue.

Name: **Dr. Veerayya Kalmath**
Designation: **Health officer**
Tumakuru city corporation
Tumakuru



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- Narayan E-Techno School Sy.No.279/1, Ward No.19, Sharadha Devi Nagar Extn, Tumkur Town, Tumakuru District-572103				Report date: 12/06/2025 Report Number: 0013 Reference: TRF Sample code: 0013 Date of Sample collection: 11/06/2025 Analysis start date: 11/06/2025 Analysis completion date: 12/06/2025 Sample quantity: 1 Liter	
Sample Particulars: R O water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.0	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	90	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	50	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	17.2	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	16.0	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	3.2	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	2.0	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	7.5	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	4.5	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.5	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	1.7	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S Senior Analyst/Junior Analyst			Authorized Signatory: Technical Manager: Pavithra B.S		



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) **Traceability:** Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---