

No. F.6/DFS/MS/School/2018/SZ/79

Dated: 10/01/18

FIRE SAFETY CERTIFICATE

Certified that Deep Public School located at Sector-D, Pocket-II, Vasant Kunj, New Delhi-110070, comprised of Basement, Ground + two upper floors was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/832 dated 08/07/2014. The school premises was re-inspected by officer concerned of this department on 20/12/2017 in presence of Mrs. Sangeeta Paul (Principal) and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 10/01/18 at New Delhi by

Ventat
(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, Deep Public School, Sector-D, Pocket-II, Vasant Kunj, New Delhi-110070
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

Issue copy

Paul
27th March, 19

Paul
Vice Principal
DEEP PUBLIC SCHOOL
Sector-D, Vasant Kunj, New Delhi-