

**OFFICE OF THE ASSTT.CHIEF WATER ANALYST  
DELHI JAL BOARD , GOVT. OF N.C.T. DELHI  
ZONAL LABORATORY, WATER WORKS NANGLOI,  
NEW DELHI-110041**

**TEST REPORT**

Water sample collected from Paramount International School, Sector-23, Dwarka , New Delhi 110075 vide Challan No. 29353 dated-10.03.2020

S. N.	Particulars	Units	Limit	S1
1.	Date of Collection / Receipt	-----	-	11-03-2020
2.	Date of Analysis	-----	-	12-03-2020
<b>PHYSICAL EXAMINATION</b>				
1.	Colour	Hazen	5-15	Clear
2.	Odour		-	No Obj.
3.	Turbidity	N.T.U.	1-5	0.80
4.	PH Value	-----	6.5-8.5	6.8
5.	Electrical Conductivity	µmho	--	260
6.	Total dissolved solids	mg/l	500-2000	155
<b>CHEMICAL EXAMINATION</b>				
1.	Phenolphthalein Alkalinity	mg/l	--	NIL
2.	Total Alkalinity	mg/l	200--600	70
3.	Total Hardness	mg/l	200--600	120
4.	Carbonate Hardness	mg/l	--	70
5.	Non Carbonate Hardness	mg/l	--	50
6.	Calcium as Ca	mg/l	--200	32
7.	Magnesium as Mg	mg/l	--	9.6
8.	Ammonia as N	mg/l	Relax	NIL
9.	Nitrite as N	mg/l	Relax.	NIL
10.	Nitrate as No <sub>3</sub>	mg/l	Relax.	3.0
11.	Sulphate	mg/l	400	24
12.	Chloride	mg/l	250--1000	16
13.	Phosphate	mg/l	---	NIL
14.	Dissolved Iron	mg/l	0.3- No Relax.	0.24
15.	Fluoride	mg/l	1--1.5	0.5
16.	Cyanide	mg/l	0.05--No Relax.	Abst
17.	Residual Chorine	mg/l	0.2--1.0	NIL
<b>BACTERIOLOGICAL EXAMINATION</b>				
1.	Coli-form per 100 ml at 37° C	MPN	0	0

**REMARKS:** On the basis of above tested parameters ,the Sample S1 can be use for drinking purpose.

*[Signature]*  
Bacteriologist  
12/3/20

*[Signature]*  
Chemist

*[Signature]*  
Asstt. Chief Water Analyst  
DELHI JAL BOARD  
Govt. of N.C.T. Delhi  
Quality Control Laboratory  
Water Works, Nangloi, Delhi-110041

*[Signature]*  
Manager  
Paramount International School  
Sector-23, Dwarka, New Delhi-110075

*[Signature]*  
Principal  
Paramount International School  
Sector-23, Dwarka, New Delhi-110075

for PARAMOUNT INTERNATIONAL SCHOOL  
Scanned with CamScanner  
CHAIRMAN





**SOUTH DELHI MUNICIPAL CORPORATION**  
**PUBLIC HEALTH DEPARTMENT: NAJAFGARH ZONE**  
**DHANSA STAND, NAJAFGARH, NEW DELHI-110043**

No. DHO/NGZ/2020/1720

Dated 16/02/2020

1. Name of the School... Paramount International School  
 Rep. By... Delhi Sanskar Bharti Shiksha Samiti (Regd)
2. School Address... Sector-23, Dwarka, New Delhi 75
3. No. of Shifts... One Timings... 8:00 AM TO 2:00 PM
1. No. of Students: Boys... 1622 Girls... 987 Total... 2609
2. No. of Staffs: Male... 83 Female... 131 Total... 214

Details of Accommodations present in the school

- Floor area/ space in the Classroom sufficient/ insufficient... Sufficient
- Classes are well lighted/ ill lighted... Well lighted
- Classrooms are well ventilated/ ill ventilated... Well ventilated
- Classes are kept / not kept neat and clean... Kept & cleaned
- Classrooms/Building require / do not require white wash etc... Not required
- Drinking water is wholesome / not wholesome... Wholesome
- Latrine arrangement is sanitary /insanitary... Sanitary from health point of view

No. of toilets seats for students

- One latrine-cum-urinal is required for 25 female students, so total is... Sufficient
- One latrine for 40 male students is required so total is... Sufficient
- Separate toilet arrangement for staff yes / no... Yes exist separate for staff
- The overall facilities good/adequate/inadequate... V-Good from health point of view & valid upto one year from date of issuance

If Building Department or any other Govt. agency takes actions against w/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.

*[Signature]*  
 Dy. Health Officer  
 Najafgarh Zone

*[Signature]*  
 Manager

Paramount International School  
 Sector-23, Dwarka, New Delhi-110075

*[Signature]*  
 Principal

Paramount International School  
 Sector-23, Dwarka, New Delhi-110075

for PARAMOUNT INTERNATIONAL SCHOOL

*[Signature]*  
 CHAIRMAN